



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 92593
Date Reported: 4 Jan 12
Date Completed: 4 Jan 12
Date Received: 3 Jan 12 15:48

92593-01 1773 Country Rd LQRV water system

Sampled By: D. Glenn Pady
Sampling Date: 3 Jan 12 12:33

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

92593-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NISL | 1/3/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NISL | 1/3/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

1/4/2012 16:46

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 97772
Date Reported: 5 Sep 12
Date Completed: 5 Sep 12
Date Received: 4 Sep 12 16:15

97772-01 1826 Martini Way LQRV

Sampled By:

Sampling Date: 4 Sep 12 14:45

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

97772-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 9/4/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 9/4/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

9/5/2012 16:42

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 97588
Date Reported: 28 Aug 12
Date Completed: 28 Aug 12
Date Received: 27 Aug 12 16:53

97588-01 1773 Country Road LQRV

Sampled By:

Sampling Date: 27 Aug 12 12:30

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

97588-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 8/27/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 8/27/2012 |

Approved By:

Ramona S, Lab Tech

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

8/28/2012 11:28

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 97368
Date Reported: 21 Aug 12
Date Completed: 21 Aug 12
Date Received: 20 Aug 12 11:44

97368-01 1545 Pady Place LQRV

Sampled By:

Sampling Date: 20 Aug 12 0:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

97368-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 8/20/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 8/20/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

8/21/2012 15:57

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 97241
Date Reported: 15 Aug 12
Date Completed: 15 Aug 12
Date Received: 13 Aug 12 16:57

97241-01 1625 Meadowood Way LQRV

Sampled By:

Sampling Date: 13 Aug 12 13:45

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

97241-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 8/14/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 8/14/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

8/15/2012 12:09

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 97083
Date Reported: 8 Aug 12
Date Completed: 8 Aug 12
Date Received: 7 Aug 12 13:11

97083-01 1826 Martini Way LQRV

Sampled By:

Sampling Date: 7 Aug 12 12:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

97083-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 8/7/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 8/7/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

8/8/2012 13:40

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 96910
Date Reported: 31 Jul 12
Date Completed: 31 Jul 12
Date Received: 30 Jul 12 13:46

96910-01 1776 Meadowood Way LQRV washrooms

Sampled By:

Sampling Date: 30 Jul 12 11:20

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

96910-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/30/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/30/2012 |

Approved By:

Ramona S, Lab Tech

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

7/31/2012 11:42

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 96846
Date Reported: 27 Jul 12
Date Completed: 27 Jul 12
Date Received: 26 Jul 12 15:02

96846-01 Reservoir Dip LQRV

Sampled By:

Sampling Date: 26 Jul 12 12:20

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

96846-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NiSL | 7/26/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NiSL | 7/26/2012 |

Approved By:

Melissa McIntosh, Lab Technician

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

7/27/2012 14:48

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 96732
Date Reported: 26 Jul 12
Date Completed: 26 Jul 12
Date Received: 23 Jul 12 10:20

96732-01 1545 Pady Pl LQRV

Sampled By:

Sampling Date: 23 Jul 12 9:11

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

96732-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/23/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/23/2012 |

Approved By:

Kerri Scott, Lab Technician

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

7/26/2012 10:35

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 96594
Date Reported: 17 Jul 12
Date Completed: 17 Jul 12
Date Received: 16 Jul 12 12:01

96594-01 1625 Meadowood Way LQRV

Sampled By:

Sampling Date: 16 Jul 12 10:30

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

96594-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NiSL | 7/16/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NiSL | 7/16/2012 |

Approved By:

Ramona S, Lab Tech

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

7/17/2012 11:00

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 96593
Date Reported: 17 Jul 12
Date Completed: 17 Jul 12
Date Received: 16 Jul 12 12:00

96593-01 Reservoir Dip LQRV

Sampled By:

Sampling Date: 16 Jul 12 10:30

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | 13.7 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

96593-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/16/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/16/2012 |

Approved By:

Ramona S, Lab Tech

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

7/17/2012 16:47

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 96531
Date Reported: 13 Jul 12
Date Completed: 13 Jul 12
Date Received: 12 Jul 12 13:10

96531-01 Reservoir LQRV

Sampled By:

Sampling Date: 12 Jul 12 0:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | 11.1 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

96531-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/12/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/12/2012 |

Approved By:

Ramona S, Lab Tech

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

7/13/2012 14:19

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 96445
Date Reported: 10 Jul 12
Date Completed: 10 Jul 12
Date Received: 9 Jul 12 15:00

96445-01 1827 Martini Way LQRV

Sampled By:

Sampling Date: 9 Jul 12 13:30

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

96445-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/9/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/9/2012 |

Approved By:

Ramona S, Lab Tech

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC


> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

7/10/2012 11:01

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 96298
Date Reported: 4 Jul 12
Date Completed: 4 Jul 12
Date Received: 3 Jul 12 15:10

96298-01 1773 Country Road

LQRV

Outside Tap

Sampled By:

Sampling Date: 3 Jul 12 13:15

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

96298-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/4/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 7/4/2012 |

Approved By:

Ramona S, Lab Tech

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

7/4/2012 13:16

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 96131
Date Reported: 27 Jun 12
Date Completed: 27 Jun 12
Date Received: 25 Jun 12 15:51

96131-01 1545 Pady Pl.

LQRV

Outside Tap

Sampled By:

Sampling Date: 25 Jun 12 12:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

96131-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 6/25/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 6/25/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

6/27/2012 15:32

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 95982
Date Reported: 19 Jun 12
Date Completed: 19 Jun 12
Date Received: 18 Jun 12 16:56

95982-01 1625 Meadowood Lane

LQRV

Outside Tap

Sampled By:

Sampling Date: 18 Jun 12 16:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

95982-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 6/18/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 6/18/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

6/19/2012 13:52

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 95849
Date Reported: 12 Jun 12
Date Completed: 12 Jun 12
Date Received: 11 Jun 12 15:17

95849-01 1545 Pady Place

LQRV

Outside Tap

Sampled By:

Sampling Date: 11 Jun 12 14:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

95849-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 6/11/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 6/11/2012 |

Approved By:

Ramona S, Lab Tech

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

6/12/2012 12:57

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 95742
Date Reported: 6 Jun 12
Date Completed: 6 Jun 12
Date Received: 5 Jun 12 15:39

95742-01 1545 Pady Place

LQRV

Outside Tap

Sampled By:

Sampling Date: 4 May 12 16:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

95742-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 6/5/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 6/5/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

6/6/2012 12:03

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 95542
Date Reported: 29 May 12
Date Completed: 29 May 12
Date Received: 28 May 12 16:38

95542-01 Reservoir LQRV

Sampled By:

Sampling Date: 28 May 12 15:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

95542-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/28/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/28/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

5/29/2012 12:49

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 95541
Date Reported: 29 May 12
Date Completed: 29 May 12
Date Received: 28 May 12 16:37

95541-01 1625 Meadowood Way LQRV

Sampled By:

Sampling Date: 28 May 12 15:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

95541-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/28/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/28/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

5/29/2012 12:49

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 95468
Date Reported: 25 May 12
Date Completed: 25 May 12
Date Received: 24 May 12 16:47

95468-01 1776 Country Road LQRV

Sampled By:

Sampling Date: 24 May 12 16:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

95468-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/24/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/24/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC


> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

5/25/2012 13:43

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 95385
Date Reported: 23 May 12
Date Completed: 23 May 12
Date Received: 22 May 12 14:15

95385-01 1773 Country Road LQRV

Sampled By:

Sampling Date: 22 May 12 13:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | 2.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

95385-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/22/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/22/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

5/23/2012 11:42

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 95254
Date Reported: 15 May 12
Date Completed: 15 May 12
Date Received: 14 May 12 16:53

95254-01 Well # 9

LQRV

Sampled By:

Sampling Date: 14 May 12 15:40

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

95254-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/14/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/14/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

5/15/2012 13:09

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 95253
Date Reported: 15 May 12
Date Completed: 15 May 12
Date Received: 14 May 12 16:52

95253-01 1554 Pady PI LQRV

Sampled By:

Sampling Date: 14 May 12 15:20

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

95253-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NiSL | 5/14/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NiSL | 5/14/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

5/15/2012 13:09

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 95102
Date Reported: 8 May 12
Date Completed: 8 May 12
Date Received: 7 May 12 15:17

95102-01 1625 Meadowood Way LQRV

Sampled By:

Sampling Date: 7 May 12 14:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

95102-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/7/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 5/7/2012 |

Approved By:

Ramona S, Lab Tech

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

5/8/2012 15:15

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 94944
Date Reported: 1 May 12
Date Completed: 1 May 12
Date Received: 30 Apr 12 16:42

94944-01 1826 Martini Way

Lot 248 LQRV

Outside Tap

Sampled By:

Sampling Date: 30 Apr 12 15:45

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

94944-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 4/30/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 4/30/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

5/1/2012 12:26

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 94774
Date Reported: 24 Apr 12
Date Completed: 24 Apr 12
Date Received: 23 Apr 12 15:38

94774-01 1773 Country Road

Well

Outside Tap

Sampled By:

Sampling Date: 23 Apr 12 14:30

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

94774-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 4/23/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 4/23/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

4/24/2012 11:51

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 94628
Date Reported: 17 Apr 12
Date Completed: 17 Apr 12
Date Received: 16 Apr 12 17:00

94628-01 1545 Pady Pl LQRV Water System

Sampled By:

Sampling Date: 16 Apr 12 15:50

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

94628-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NiSL | 4/16/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NiSL | 4/16/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

4/17/2012 12:15

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 94498
Date Reported: 11 Apr 12
Date Completed: 11 Apr 12
Date Received: 10 Apr 12 15:43

94498-01 1625 Meadowood Way LQRV Water System

Sampled By:

Sampling Date: 10 Apr 12 13:45

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

94498-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 4/10/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 4/10/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

4/11/2012 16:55

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 94357
Date Reported: 3 Apr 12
Date Completed: 3 Apr 12
Date Received: 2 Apr 12 16:46

94357-01 1826 Martini Way LQRV Water System

Sampled By:

Sampling Date: 2 Apr 12 15:45

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

94357-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NiSL | 4/2/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NiSL | 4/2/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

4/3/2012 15:12

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 94222
Date Reported: 28 Mar 12
Date Completed: 28 Mar 12
Date Received: 27 Mar 12 16:10

94222-01 1773 Country Rd LQRV Water System

Sampled By:

Sampling Date: 27 Mar 12 15:10

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

94222-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 3/27/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 3/27/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

3/28/2012 12:45

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 93914
Date Reported: 14 Mar 12
Date Completed: 14 Mar 12
Date Received: 13 Mar 12 11:40

93914-01 1625 Meadowood Way LQRV Water System

Sampled By:

Sampling Date: 12 Mar 12 12:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

93914-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 3/13/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 3/13/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

3/14/2012 10:33

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 94071
Date Reported: 22 Mar 12
Date Completed: 22 Mar 12
Date Received: 20 Mar 12 16:34

94071-01 1545 Pady Place

LQRV Water System

Sampled By:

Sampling Date: 20 Mar 12 15:33

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

94071-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 3/20/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 3/20/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

3/22/2012 11:43

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 93783
Date Reported: 6 Mar 12
Date Completed: 6 Mar 12
Date Received: 5 Mar 12 16:40

93783-01 1826 Martini Way SL248 LQRV Water System

Sampled By:

Sampling Date: 5 Mar 12 15:51

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

93783-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 3/5/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 3/5/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

3/6/2012 12:32

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Db. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 93487
Date Reported: 22 Feb 12
Date Completed: 22 Feb 12
Date Received: 20 Feb 12 16:47

93487-01 1545 Pady Pl. Lot 178 LQRV Water System

Sampled By:

Sampling Date: 20 Feb 12 13:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

93487-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 2/20/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 2/20/2012 |

Approved By: Catherine Black
Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

2/22/2012 12:51

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 93352
Date Reported: 14 Feb 12
Date Completed: 14 Feb 12
Date Received: 13 Feb 12 16:41

93352-01 1625 Meadowood Way LQRV Water System

Sampled By:

Sampling Date: 13 Feb 12 12:30

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

93352-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 2/13/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 2/13/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

2/14/2012 13:20

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 93215
Date Reported: 8 Feb 12
Date Completed: 8 Feb 12
Date Received: 6 Feb 12 17:06

93215-01 1826 Martini Way LQRV Water System

Sampled By:

Sampling Date: 6 Feb 12 16:10

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

93215-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 2/7/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 2/7/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

2/8/2012 12:34

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 93054
Date Reported: 31 Jan 12
Date Completed: 31 Jan 12
Date Received: 30 Jan 12 16:31

93054-01 1773 Country Rd LQRV Water System

Sampled By:

Sampling Date: 30 Jan 12 0:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

93054-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NISL | 1/30/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NISL | 1/30/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

2/21/2012 10:28

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 92927
Date Reported: 25 Jan 12
Date Completed: 24 Jan 12
Date Received: 23 Jan 12 16:11

92927-01 1545 Pady Place LQRV Water System

Sampled By:

Sampling Date: 23 Jan 12 13:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

92927-01

For further information regarding sampling, lab results and well disinfection, please check our web site:
<http://www.nilabs.com>. For information on wells and ground water see: www.wellwaterprotection.bc.ca
We suggest the following Health Canada website for further information regarding the latest drinking water quality guidelines to help you assess your results:
<http://www.hc-sc.gc.ca/ewh-semt/water-eau/drink-potab/guide/index-eng.php>

Total Coliform: The Total Coliform group (of micro-organisms) includes: The fecal coliform (E.coli), which are common to the intestinal tract of both man and animals, and the non-fecal coliforms that are naturally present in soils and on vegetation. The precise sanitary significance of the Total Coliform test may be difficult to establish. The test is offered as an indicator of bacterial contamination.

E.coli: E.coli has been shown to be an indicator of the potential presence of enteric pathogens in water. The maximum acceptable concentration (MAC) of E. coli in drinking water is none detectable per 100 mL. Any untreated supply that contains E.coli should receive disinfection.

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 1/23/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 1/23/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

1/25/2012 12:11

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 92846
Date Reported: 17 Jan 12
Date Completed: 17 Jan 12
Date Received: 16 Jan 12 16:36

92846-01 1625 Meadowood Way LQRV water system

Sampled By: D. Glenn Pady

Sampling Date: 16 Jan 12 0:00

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

92846-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|-----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 1/16/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 1/16/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

1/17/2012 11:39

Page 1 of 1



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: 648613 BC LTD
Dba. Pady Consulting
Candice Pady
1339 Meadowood Way
Qualicum Beach, BC V9K 2S4

Lab Number: 92707
Date Reported: 10 Jan 12
Date Completed: 10 Jan 12
Date Received: 9 Jan 12 16:41

92707-01 1826 Martini Way lot 248 LQRV water system

Sampled By: D. Glenn Pady
Sampling Date: 9 Jan 12 12:30

| Test | Result | Units | Drinking Water Guideline |
|-----------------------|--------|-----------|--------------------------|
| Total Coliforms (DES) | <1.0 | MPN/100mL | <1 |
| E. coli (DES) | <1.0 | MPN/100mL | <1 |

92707-01

| Test | Method | Analyst | Date |
|-----------------------|---|---------|----------|
| E. coli (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 1/9/2012 |
| Total Coliforms (DES) | Enzyme Substrate, APHA 9223 B -modified | NIsL | 1/9/2012 |

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

1/10/2012 12:31

Page 1 of 1